



**GREATER VISAKHAPATNAM MUNICIPAL CORPORATION**  
**FIRE PREVENTION WING**

From:  
The Commissioner,  
Greater Visakhapatnam  
Municipal Corporation,  
Visakhapatnam.

To:  
The District Educational Officer,  
Visakhapatnam District,  
Visakhapatnam

**Rc.No.358/RFO/FPW/GVMC/2023, Dt.25-10-2023**

**SUB:** Greater Visakhapatnam Municipal Corporation - Fire Prevention Wing- Existing Building of **M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam - Revised Renewal of Fire No Objection Certificate- Issued - Regarding.**

- REF:** 1. Letter Rc.No:5041/B2/97 of Director General, A.P.Disaster Response & Fire Services Department, Dated: 12-03-2010.  
2. Delegation orders of the Commissioner, GVMC vide Rc.No.6721/2012/TP. Sec/G1 Dt:13/09/2019.  
3. This Office Fire No Objection Certificate for Occupancy vide Rc.No.6059/14/FPW/GVMC, Dt.01-05-2014.  
4. This Office Renewal of Fire No Objection Certificate issued vide Rc.No.00226/20/FPW/GVMC, Dt.27-10-2020.  
5. Application Dated:18-10-2023 of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam for Revised Renewal of Fire NOC.

\*\*\* \*\*

It is to inform that vide reference 4<sup>th</sup> cited, Renewal of Fire No Objection Certificate was issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam.

2) Vide reference 5<sup>th</sup> cited, an application is received by this office for issuance of Revised Renewal of Fire No Objection Certificate duly changing Plot area in the NOC.

3) Therefore, the District Fire Officer and Station Fire Officer of Fire Prevention Wing visited the premises of M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam on 19-10-2023 and submitted the following report.

4) Particulars of The building:

a)	Address of the Premises	M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam
b)	Total Plot Area	6,177.00 Sq. Mtrs (Block-I & II)
c)	Height of the Building	13.00Mtrs
d)	No of blocks/ floors	02 Blocks / Stilt + Ground + 02 Upper Floors
e)	Type of occupancy	Educational Building (School)

**BLOCK-I**


5) The floor wise details.

Sl.No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground	443.10	Educational (School)
2.	First	508.38	Educational (School)
3.	Second	483.82	Educational (School)
4.	Third	483.82	Educational (School)
	Total	1919.12	

6)The Builder has provided the following open places all round building.

Direction	Open space provided
North (Front)	2.70
South	7.50
East	4.00
West	2.70

Contd.p.2



**Correspondent**  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)



*S. Sharanathi*  
**Principal (I/C)**  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)

## 7) Means Escape:

- The Management has provided One Internal Staircase with width of 1.20 Mtrs. from Ground floor to Terrace.

8) The Minimum Fire Safety Installations required & provided by the Builder as per the Table-23 and other relevant clauses of part-4 of N.B.C of India 2005.

Sl.No.	Fire Safety Measures	Required	Provided	Deficit
1	Fire Extinguishers as per IS 2190	19 No's	19 No's	Nil
2	Hose Reel	04 Nos.	04 Nos.	Nil
3	Down comer	01 No.	01 No.	
4	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
5	Booster Pump	450 LPM	450 LPM	Nil

**BLOCK-II**

## 9) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground	277.96	Educational (School)
2.	First	277.96	Educational (School)
3.	Second	277.96	Educational (School)
4.	Third	277.96	Educational (School)
	Total	1111.84	

## 10) The Builder has provided the following open places all round building.

Direction	Open space provided
North (Front)	2.70
South	7.00
East	2.00
West	4.00

## 11) Means Escape:

- The Management has provided One Internal Staircase & One External Staircase with width of 1.00 Mtr. each from Ground floor to Terrace.

12) The Minimum Fire Safety Installations required & provided by the Builder as per the Table -23 and other relevant clauses of part-4 of N.B.C of India 2005.

Sl. No.	Fire Safety Measures	Required	Provided	Deficit
1	Fire Extinguishers as per IS 2190	12 No's	12 No's	Nil
2	Hose Reel	04 Nos.	04 Nos.	Nil
3	Down comer	01 No.	01 No.	Nil
4	Terrace Tank	10,000 Ltrs.	10,000 Ltrs.	Nil
5	Booster Pump	450 LPM	450 LPM	Nil

13) The management has remitted an amount of Rs.3,031/- vide challan No.2023-CA-053607, Dt.18-10-2023 towards fire precautionary fees for Revision of Plot area in NOC.

14) The District Fire Officer & Station Fire Officer, Fire Prevention Wing, GVMC visited the site and recommended for issuance of Revised Renewal of Fire No Objection Certificate.

15) Therefore, **Revised Renewal of Fire No Objection Certificate** is hereby issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam subject to the following conditions:

i.	All the protection arrangements shall be maintained in good condition as seen during inspection
ii.	All the escape / exit routes shall not be kept locked / blocked or encroached
iii.	All the occupants must know the correct method of operation of the fire fighting system installed
iv.	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.
v.	All students / staff members of the institution shall be trained to operate the fire safety equipments during Emergency.
vi.	Addition / alteration, if any in the building may be obtained with prior permission from this department.

Contd.p..3

  
Correspondent  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)



  
Principal (I/C)  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)



- vii. Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

- 16) The **Revised Renewal of Fire No Objection Certificate** issued to M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam **is valid from 18-11-2020 to 17-11-2025** and the **Management shall submit the application for Renewal of Fire No Objection Certificate two (2) months before the date of expiry.**
- 17) The issuing of Fire NOC is without any prejudice to take action by GVMC against Unauthorized Construction, if any made.



*[Signature]*  
**Regional Fire Officer**  
**Fire Prevention Wing,**  
**Greater Visakhapatnam Municipal Corporation,**  
**Visakhapatnam**

**Copy to:**

- 1) The Chief City Planner, GVMC, Visakhapatnam.
- 2) The Management, M/s.Apple I E.M. School (Block-I & II), D.No.27-1-203/2, Sy.No.118/1 to 5, Srinagar, Gajuwaka, Visakhapatnam

Digitally Signed by Y  
Hanumantha Rao  
Date: 25-10-2023 16:57:45  
Reason: Approved

*[Signature]*  
**Correspondent**  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)



*[Signature]*  
**Principal (I/c)**  
**APPLE I EM SCHOOL**  
Srinagar, Gajuwaka (P.O.)  
Visakhapatnam-530 026 (A.P.)